



BOSCH

IAQ SERIES HUMIDIFIER VAPOR PAD REPLACEMENT INSTALLATION INSTRUCTIONS

INSTALLATION

This evaporator pad is designed to fit the HUMBSBP-12H6--A or HUMBLBP-17H6--A humidifier models. The evaporator pad is coated with a non-soluble wetting agent to increase humidifier efficiency. Some of the coating may dust off during transit. This will not affect the efficiency of the evaporator pad.

To replace a used pad, remove the front cover by pulling the snap on the bottom/underside of the cover out & down (Figure 2). Lift the cover off the tabs on top (Figure 1). Remove the vapor pad assembly (includes the trough, drain pan and vapor pad) from the humidifier. Lift the trough off the top and slide used pad out of drain pan.

Clean excessive mineral deposits from trough and drain pan. Flush mineral deposits out of drain hose to prevent overflow condition during heating season.

With black patch on vapor pad on the top (opposite side of the drain pan, see Figure 3), place the evaporator pad into drain pan. Replace trough. Install pad assembly, etc. Replace cover by first aligning the top "tabs" and then "Snapping" the cover back on.

If humidifier has been in service for more than three years, remove the strainer assembly at the inlet of the solenoid valve. Pull the orifice fitting from the outlet of the solenoid valve and clean all parts. If the orifice is clogged, it may be opened by inserting a small needle.

Start air handler blower and check operation of unit after servicing. Ensure no leaks are present before leaving.




Figure 1




Figure 2




Figure 3

Humidifier Model	Replacement Evaporator Pad Part
HUMBSBP-12H6--A	7738002906
HUMBLBP-17H8--A	7738001907

For technical support or replacement parts, contact:

Bosch Group

(954) 776-5471

Monday-Friday: 8am – 5 pm EST

601 N.W. 65th Court

Ft. Lauderdale, FL 33309



BOSCH

601 N.W. 65th Court, Ft. Lauderdale, FL 33309

Phone: 954-776-5471 | Fax: 954-776-5529

www.bosch-climate.us

6720220350 Revised 07-12